



NOTES: 1) STEEL CASING IS REQUIRED (MIN. 3/8" WALL THICKNESS) FOR ALL BORES GREATER THAN 4" DIA.

2) A MINIMUM OF 5' OF COVER IS REQUIRED OVER ALL BORED PIPING/CONDUIT

BORING & JACKING

NOT TO SCALE

3/9/99

REVISED